

CB TEST CERTIFICATE

Ref. Certificate No.

NL-30233

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR **ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**

Issued by:

DEKRA Certification B.V.

Product:

Moulded-case circuit-breaker

Applicant:

Factory:

Shanghai Ebasee

No.18 Gutang Road, Pudong,

China

Electric Co., Ltd

Shanghai, 201209

SASSIN Manufacturer: INTERNATIONAL

NO. 2588, JINHAI ROAD, PUDONG, SHANGHAI,

China

ELECTRIC SHANGHAI

201209

CO., LTD

SASSIN

NO. 2588, JINHAI ROAD,

China

INTERNATIONAL

ELECTRIC SHANGHAI

PUDONG, SHANGHAI, 201209

CO., LTD

Rating and principal

characteristics:

3P / 4P: Ue = 400 Vac:

In = 160 A, 180 A, 200 A, 225 A, 250 A; Uimp = 6 kV;

Ui = 500 V:

Icu = 50 kA, Ics = 75% Icu (EBS7M-250S);Icu = 35 kA, Ics = 100% Icu (EBS7M-250N);

50/60 Hz; Utilization Category A

Trade mark (if any):

EBASEE

Model/Type reference:

EBS7M-250S, EBS7M-250N

Additional information:

This certificate is based on CB certificate No. NL - 18018 issued on 2010-04-09.

Tests were conducted in 2010.

Sample of product tested to be in conformity with IEC:

60947-1(ed.5) 60947-2(ed.4);am1

Test Report Ref. No:

3300912.50 and 3306173.50

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem

The Netherlands

DEKRA

Signed by: F.S.Strikwerda

Date of issue: 2014-03-21